UPDATED: 7 April 2004

BERTHING SPRINKLER SYSTEM (MHC ONLY) CHECK SHEET

FOR USS _____

DATE:_____

REF: (A) PMS 5221/
(B) NSTM 555 V1
(C) GSO 521

	IAW	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT
COMPARTMENT NUMBER													
A. INSPECT BERTHING SPRINKLING SYSTEM PIPING AND COMPONENTS:	5221/015												
1. Verify there is no leakage on the following components:	2W-1R												
a. Fire main supply root cutout valve?	2W-1R												
b. 2-way control valve?	2W-1R												
2. Is the 2-way control valve in the open position with the locking key installed?	2W-1R												
3. Ensure the firemain supply cutout valve is in the open position?	2W-1R												
B. INSPECT SPRINKLER HEADS:	5221/015												
1. Are the sprinkler heads free of paint, dust and dirt?	S-2R												
2. Is there any damage to the sprinkler heads, (broken arms or deflectors)?	S-2R												
3. Is the glass bulb the right type?	GSO 521												
4. Is there any signs of leakage on the heads?	S-2R												
C. MANUAL CONTROL VALVE:	5221/015												
1. Is the manual control valve free of dirt and verdigris?	S-1R												

REMARKS:

ASSESSOR(S):_____DATE: _____