UPDATED: 7 April 2004

DC OVERBOARD DISCHARGE CONNECTION FITTINGS CHECK SHEET
FOR USS _____
DATE:_____

REF: (A) PMS 6641/003
(B) SHIPS DC BOOK
(C) NSTM 593 POLLUTION CONTROL AND ABATEMENT
(E) NSTM 079V2

	IAW	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT
LOCATION: **FITTING NUMBER:**														
A. INSPECT DISCHARGE CONNECTION:														
1. Are thread on the 2.5' fitting and the 4' fitting in good condition? - Treads were damaged.	S-1													
2. Was the fitting properly classified and did it have the proper label plates? - DC overboard discharge connection fitting was not properly labeled. -Pollution control label was not posted.	REF: (B), (C), & (E)													
3. Were the coupling gaskets in good condition? - Gaskets were dry rotted. - Gasket was damaged. - Gaskets were cut.	S-1													
4. Were couplings in good condition and cycled freely? - Coupling was corroded. - Coupling was heavily gammed with debris? - 2.5' Coupling did not cycle freely. - 4' coupling did not cycle freely. - Coupling was not properly greased.	S-1													
5. Were spanner wrenches on station?														

REMARKS:	

ASSESSOR(S):_____ DATE: _____