UPDATED: 30 July 2004

SMOKE DETECTOR SYSTEM CHECK SHEET
USS _____
DATE: _____

REF: (A) PMS 4361/002 LHD'S MRC A-5
(B) PMS 4361/051 DDG'S MRC A-4

	IAW	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT	SAT/ UNSAT
COMPARTMENT NUMBER														
PRIMARY OR RESERVE														
A. INSPECT SMOKE DETECTOR:														
1. Was the detector in good condition? No hanging wires, no paint overspray on detector screen, not missing?	**A-4 A-5**													
B. TEST SMOKE DETECTOR: (DDG'S)														
Warning: DO NOT USE SMOLDERING MATERIAL FOR SMOKE DETECTORS IN SPACE WITH FLAMMABLE LIQUIDS. USE SMOKE DETECTOR TESTER SPRAY.														
1. For plasma screens: Did message appear on screen?	**A-4,**													
2. Did smoke detector alarm acknowledge push button illuminate? Did indicator extinguish when pressed?	**A-4,**													
3. Did smoke detector alarm in CCS at DC console (audible 4 hz)? Did audible alarm silence when acknowledged?	**A-4,**													
4. Did ITB (interface terminal box) illuminate.	**A-4**													
5. Was PMS installed in ship's 3M? In proper work center decks?	**A-4**													
C. TEST SMOKE DETECTOR: (LHD'S)														
Warning: DO NOT USE SMOLDERING MATERIAL FOR SMOKE DETECTORS IN SPACE WITH FLAMMABLE LIQUIDS. USE SMOKE DETECTOR TESTER SPAY.														
1. Did alarm activate at switchboard on Zone Module applicable for detector(s)?	**A-5**													
2. Did audible horn wail? (Power control panel (PCP) red "alarm" LED flash and zone module's red "alarm" LED applicable for detector flash?)	**A-5**													
3. Did smoke detector's red "alarm" LED energize?	**A-5**													
4. Did horn silence when PCP acknowledge push button was depressed? Did PCP red "alarm" LED glow steadily?	**A-5**													
5. Was PMS installed in ship's 3M? In proper work center decks?	**A-5**													

REMARKS:

ASSESSOR(S):_____ _____ DATE: _____