DCST-003-CFIRE-02

FIRE - CLASS "C"

REPORTED ENGAGED NO

SOUNDS OF DAMAGE
TRACK 17 CHARLIE FIRE

FLAGS TO DISPLAY

REPORTED

C

TIME 1630 NUMBER 1

FROM TO

X FM - INV - SL
DCRS 2
DCRS 3 X
DCRS 5
DCC

COMPT. #/NAME 2-438-2-A

FRAME 441

REMARKS:



BOUNDARIES	S	P	P	S
FB - SB - FLB - CB				

ENGAGED

C

TIME 1636 NUMBER 2

FROM TO

X FM - INV - SL
DCRS 2
DCRS 3 X
DCRS 5
DCC

COMPT. #/NAME 2-438-2-A

FRAME 441

REMARKS:



BOUNDARIES	S	P	P	S
FB - SB - FLB - CB				

NO

C

TIME 1641 NUMBER 3

FROM TO

X FM - INV - SL
DCRS 2
DCRS 3 X
DCRS 5
DCC

COMPT. #/NAME 2-438-2-A

FRAME 441

REMARKS:



BOUNDARIES	S	P	P	S
FB - SB - FLB - CB				

Three different examples of manual plotting









FIRE - CLASS “C"

CASUALTY ACTIONS AT SCENE

REPORTED

SIZE IT UP
Casualty initial reports, assessment, evaluation and information.
What do I have

Reported (Size It Up)
STEPS
Space Name, Number, Accessible
Class , Size, Cause of fire,
Location within the space (chit)
Determine Additional Hazards
Fixed Fire protection features Avail (CO2 hose reel, fresh water hose)
Any personnel casualties
Immediate resources available (fire stations, fix systems ect.)
Hidden and Secondary damage
Report

ENGAGED

FIGHT IT
Casualty engagement
What am I doing to make progress

Engaged (Fight It)
STEPS
Isolate power source
Equipment selected and layed out
Team brief of tactic
Operational equipment check
Team execution
Stop fire spread, remove combustible, apply agent, establish and maintain the box
Re-evaluate situation
Re-apply agent

NO

MONITOR IT
The fight is complete,
No further spread, Clean it up

No (Monitor It)
STEPS
Fire is out
Re-check the box
Secondary operations (overhaul, reflash watch, desmoke, atmospheric testing,)
damage assessment
Debrief team